



# Compliance Statement

## Screened Category 7 ISO/IEC, EN & Enhanced ANSI/TIA Communication Cable

**Telegärtner P/N L0200A0123 / L02002A0120**

Category 7, Two Individual Foil and Overall Braid Screened Unit  
100  $\Omega$ , 2x4 Twisted Pairs, 23 AWG, Flame Retardant, LSHF, Copper Cable

**Telegärtner Karl Gärtner GmbH**  
**Lerchenstrasse 35**  
**D-71144 Steinenbronn, Germany**

*Compliance Statement No. 111631A*

*This Screened ISO/IEC, EN & Enhanced ANSI/TIA Communication Cable has been tested by 3P Third Party Testing and complies with the Category 7 performance requirements of edition 2.2 of ISO/IEC Generic Cabling Standard 11801, CENELEC Generic Cabling Standard EN 50173-1:2011, the Category 6<sub>A</sub> requirements of ANSI/TIA Generic Cabling Standard 568-C.2, 2<sup>nd</sup> edition IEC Cable Standard 61156-5, and the requirements of 2<sup>nd</sup> edition CENELEC Cable Standard EN 50288-4-1. Flame safety is verified according to IEC 60332-1-2, IEC 61034-1, IEC 61034-2, incl. amendment.1 and IEC 60754-2 The cable has EMC Performance Rating 9. The Compliance Statement may be suspended or withdrawn if cable fails to pass a Maintenance Testing performed at 6 or 12 month intervals.*

Hoersholm, 27<sup>th</sup> January 2012

A handwritten signature in blue ink, appearing to read "Ole Lambertsen".

Ole Lambertsen  
Test Responsible

Hoersholm, 27<sup>th</sup> January 2012

A handwritten signature in blue ink, appearing to read "Poul Villien".

Poul Villien  
Coordinating Manager